

Robinson  
Meier  
Juilly & Associates

Principals  
*Peter Robinson, S.E.*  
*Jayson E. Haines, S.E.*



## 10-Series Unit

## Structural Calculations For Seismic Anchorage

Prepared for:

Crenlo  
April 06, 2016  
Updated June 25, 2018  
RMJ Job No. 14273 & 18183  
Valid Thru December 31, 2019





# 10-Series Units

## Table of Contents

<u>Description</u>	<u>Page</u>
Project Description/Results.....	3
Scope, Assumptions, Limitations .....	4
Drawing Design Scenarios Summary.....	5
Seismic Risk Map .....	6
G-Series Unit Anchorage Flow Charts .....	7-10
Low& Moderate Seismic Calcs.. .....	11-20
High Seismic Calcs.. .....	21-30
Drawings Details.....	31-40
Appendix.....	41-51
Hilti Output File (Shear).....	42-46
Hilti Output File (Tension) .....	47-51



10-Series Unit Anchorage  
Nationwide  
RMJ Job# 14273

**Project Description:**

This project involves providing server anchorage support for units located throughout the United States. Calculations have been assembled according to two distinct seismic regions low & moderate, and high. A map has been created based on Figures 3.3-1 & 3.3-2 of ASCE 7-10 to define the two different seismic regions. Please note our seismic map shows three distinct regions low, moderate, and high, but for simplicity of our calculations low and moderate were combined into one region. The map also shows a solid line near the New Madrid Fault where the value of  $S_s$  exceeds 2.75. In this area of extreme seismic potential, all anchorage is site specific. The other seismic regions have been determined according to the table included below;

<i>Seismic Design Data</i>			
Seismic design region	Short period spectral response acceleration $S_s$	Short-period site coefficient $F_a$	Design spectral response acceleration at short periods $S_{DS}$
Low	0.4	1.5	0.4
Moderate	1.5	1.0	1.0
High	2.75	1.0	2.0

**Anchorage**

Calculations are based ½" diameter Hilti Kwik Bolt KB-TZ Carbon Steel expansion bolts, with the assumptions that anchors are not located within any boundary edges, 4" thick concrete minimum thickness, 2" minimum embedment, and 3,000 psi concrete strength. See table below for allow cabinet + content weight.

**Allowable Values**

MAX CABINET WT. WITH CONTENTS	LOW & MODERATE SEISMIC				HIGH SEISMIC			
	GROUND		UPPER		GROUND		UPPER	
	ON FLOOR	RAISED	ON FLOOR	RAISED	ON FLOOR	RAISED	ON FLOOR	RAISED
SINGLE UNIT	1,500	1,500	1,500	1,500	800	SS <sup>1</sup>	800	SS <sup>1</sup>
GANGED UNIT	1,500	1,200	1,300	1,300	1,200	SS <sup>1</sup>	1,100	SS <sup>1</sup>

SS<sup>1</sup>- Site Specific Calculations Required

**Anchor Capacities**

Please see the table below for a quick review of our results.

Bolt Alignment	Max Tension (lbf.)	Max Shear (lbf.)	% Capacity
Ground Level	1,275	1,490	99
50% Bld. Ht.	1,275	1,490	99

I have included the Hilti output files along with my hand calculations in the appendix section of this calculation packet. Site specific engineering is required where  $S_s$  is greater than 2.75. Design is in accordance with the 2012 International Building Code along with the 2013 California Building Code.

Robinson  
Meier  
Juilly & Associates

Principals  
Peter Robinson, S.E.  
Jayson E. Haines, S.E.


**10-Series Units by Crenlo**  
**Scope, Assumptions, and Limitations**  
**RMJ Job #14273**  
**April 4, 2015**

**Special Note:**

*Server rack anchorage calculations are valid under the 2012 International Building Code thru date noted on cover sheet. After valid thru date, contact Crenlo for updates.*

- Special Inspection shall be provided for expansion bolt installation.
- Existing concrete shall have a minimum compressive strength of 3,000 psi.
- Importance factor is assumed to be 1.0.
- Raised Units not to exceed 18".
- Soil class is assumed to be D.
- Calculations and anchorage are done in accordance with the 2012 IBC and ASCE7-10.
- Maximum  $S_s$  value is 2.75. Where value of  $S_s$  exceeds 2.75, site specific calculations are required for all anchorages.  $S_s$  values can exceed 2.75 near the New Madrid fault.
- The minimum slab on grade thickness is assumed to be 4".
- The minimum concrete fill over metal deck thickness is 3½" (with 1 ½" metal deck).
- Enclosure is assumed to stay rigid during seismic loading (design by others).
- Computer access floor shall have strength to support compression and lateral loads.
- Floor slab and concrete filled metal deck shall have strength to resist uplift caused by overturning moment of cabinets.
- Any installation located in a high seismic region above the upper half of building shall be site specific. The second floor of a 2 story building is not considered the upper half of the building.
- Ganged Units based on a Minimum of 3 Units.
- Calculations are for Crenlo 10-Series units.

# DESIGN SCENARIOS AND CONDITIONS



FASTENER SELECTION  
HILTI KB-TZ 1/2" Ø BOLT

## DESIGN CRITERIA

- PROVIDE SPECIAL INSPECTION FOR EXPANSION ANCHOR
- (E) CONC. MIN COMPRESSIVE STRENGTH 3,000 psi
- GROUND FLOOR
- INSTALLATION AT <50% OF BUILDING HEIGHT
- SINGLE & GANGED UNITS (3 OR MORE)
- HIGH, MODERATE & LOW SEISMIC REGIONS
- CALCULATION PER IBC 2012/CBC 2013
- IMPORTANCE FACTOR 1.0
- WEIGHT OF ENCLOSURE AND CONTENTS: SEE TABLE

ALLOWABLE CABINET ADDED WEIGHT \*ALL WEIGHTS GIVEN IN (LB) TABLE 1

MAX CABINET WT. WITH CONTENTS	LOW & MODERATE SEISMIC				HIGH SEISMIC			
	GROUND		UPPER		GROUND		UPPER	
	ON FLOOR	RAISED	ON FLOOR	RAISED	ON FLOOR	RAISED	ON FLOOR	RAISED
SINGLE UNIT	1,500	1,500	1,500	1,500	800	SS <sup>1</sup>	800	SS <sup>1</sup>
GANGED UNIT	1,500	1,200	1,500	1,500	1,200	SS <sup>1</sup>	1,200	800

SS<sup>1</sup> – SITE SPECIFIC ENGINEERING REQUIRED



**RMJ**

Robinson  
Meier  
Juilly & Associates  
www.rmjse.com

Structural Engineers

241 Joaquin Avenue  
San Leandro, CA 94577  
Tel: 510.991.0977

CRENLO  
10 SERIES

LOW, MODERATE, AND HIGH  
SEISMIC REGIONS

Signed by MAS

Date 04/2015

Job No.


14273

Sheet No.


(SK2)



## Summary: 10-Series - Low & Moderate Seismic




## Summary: 10-Series - Low & Moderate Seismic






## Summary: 10-Series - High Seismic



## Summary: 10-Series - High Seismic



Robinson  
Meier  
Juilly & Associates

Principals  
*Peter Robinson, S.E.*  
*Jayson E. Haines, S.E.*

# Low Seismic Calculations

241 Joaquin Avenue  
San Leandro, CA 94577  
(510) 991-0977

**Find the Seismic Design Category (SDC)****Unit : 10-Series**Project Location: Low & Moderate Seismic  
Latitude: Varies Longitude: VariesSoil Classification: D Table 1613.5.2 & Section 1613.5.2  
Occupancy Category: II Table 1604.5

Information from U.S. Geological Survey Website

<http://earthquake.usgs.gov/research/hazmaps/>

$S_S=$	1.500	g	
$S_1=$	1.070	g	
$F_a=$	1.000		Table 1613.5.3(1)
$F_v=$	1.500		Table 1613.5.3(2)
$S_{MS}=$	1.50	g	(Equation 16-37)
$S_{M1}=$	1.61	g	(Equation 16-38)
$S_{DS}=$	1.000	g	(Equation 16-39)
$S_{D1}=$	1.070	g	(Equation 16-40)

**Seismic Design Category (SDC):** **Varies**

## Load Case: Single Unit (Ground floor)

### Unit Dimensions

Width(w) (in) =	20.75
Depth(D) (in) =	17
Frame Height (in) =	82.375
Unit Weight (lb.) =	1,500

### Center of Gravity Location

Unit	Part	Weight (lbs)	X (in)	Y (in)	Z (in)
<b>10-Series</b>	Frame+Contents	1,500	8.5	10.375	41.1875

Longitudinal Anchorage Spacing (in) =	20.75
Transverse Anchorage Spacing (in) =	17


### Seismic Force

$S_{DS}$ =	1.0	Low & Moderate Seismic
$I_p$ =	1.0	(Importance)
$a_p$ =	1.0	(Cabinets)
$R_p$ =	2.5	(Cabinets)
$z/h$ =	0.0	(Ground Floor)
$F_p$ =	0.160	W
$F_{p,min}$ =	0.30	W
$F_{p,max}$ =	1.60	W

**Use  $F_p$  = 0.30 W**

$\Omega$  = 2.5 Overstrength

### 10-Series unit Plan



## Longitudinal Overturning

Overturning  
Moment =

$$0.30 (41.1875 \text{ in.} \times 1500 \text{ lbs.}) = 18,534 \text{ lb-in}$$

0.9xResisting  
Moment =

$$0.9 [1500 \text{ lbs.} \times (8.5 \text{ in.})] = 11,475 \text{ lb-in}$$

Total # of Bolts = 4

Anchorage Force =	519	lbs/per bolt
Shear Force =	563	lbs/per bolt

Anchorage and Shear Force Increased by Overstrength Factor

**Design Bolts for 519 lbs tension, 563 lbs. shear, longitudinal direction**

## Transverse Overturning

Overturning  
Moment =

$$0.30 (41.1875 \text{ in.} \times 1500 \text{ lbs.}) = 18,534 \text{ lb-in}$$

0.9xResisting  
Moment =

$$0.9 [1500 \text{ lbs.} \times (10.375 \text{ in.})] = 14,006 \text{ lb-in}$$


Total # of Bolts = 4

Anchorage Force =	273	lbs/per bolt
Shear Force =	563	lbs/per bolt

Anchorage and Shear Force Increased by Overstrength Factor

**Design Bolts for 0 lbs tension, 563 lbs. shear, transverse direction**

### 10-Series unit Plan



Drawing Reference See: SK3 & SK6

**Load Case: Single Units on 18in raised computer floor (Ground floor)**

Unit Dimensions			Raised Floor = 18 in		
Width(w) (in) =	20.75				
Depth(D) (in) =	17				
Frame Height (in) =	82.375				
Unit Weight (lb) =	1,500				
			Center of Gravity Location		
Unit	Part	Weight (lbs)	X (in)	Y (in)	Z (in)
10-Series	Frame+Contents	1,500	8.50	10.38	59.1875

Longitudinal Anchorage Spacing (in) = 20.75  
Transverse Anchorage Spacing (in) = 17

**Longitudinal Overturning**

**Overturning Moment =** 0.30 (59.1875 in. x 1500lbs.) = 26,634 lb-in

**0.9xResisting Moment =** 0.9 [1500 lbs. x (8.5in.)] = 11,475 lb-in


Total # of Bolts = 4

Anchorage Force =	1,115	lbs/per bolt
Shear Force =	563	lbs/per bolt

Anchorage and Shear Force Increased by Overstrength Factor

Seismic Force		
$S_{DS}$ =	1.0	Low & Moderate Seismic
$I_p$ =	1.0	(Importance)
$a_p$ =	1.0	(Cabinets)
$R_p$ =	2.5	(Cabinets)
$z/h$ =	0.0	(Ground Floor)
$F_p$ =	0.160	W
$F_{p,min}$ =	0.30	W
$F_{p,max}$ =	1.60	W
<b>Use <math>F_p</math> = 0.30 W</b>		
$\Omega$ =	2.5	Overstrength

**10-Series unit Plan**



**Design Bolts for 1,115 lbs tension, 563 lbs. shear, longitudinal direction**

**Transverse Overturning**

**Overturning Moment =** 0.30 (59.1875 in. x 1500lbs.) = 26,634 lb-in


**0.9xResisting Moment =** 0.9 [1500 lbs. x (10.375in.)] = 14,006 lb-in

Total # of Bolts = 4

Anchorage Force =	761	lbs/per bolt
Shear Force =	563	lbs/per bolt

Anchorage and Shear Force Increased by Overstrength Factor

**10-Series unit Plan**



**Design Bolts for 761 lbs tension, 563 lbs. shear, transverse direction**

**Drawing Reference See: SK3 & SK9**

## Load Case: Ganged Unit (Ground floor)

# of Units ganged (min.)= 3

### Single Unit Dimension

Width(w) (in) = 20.75

Depth(D) (in) = 17

Frame Height (in) = 82.375

Frame Weight (lb.) = 1,500

### Center of Gravity Location

Unit	Part	Weight (lbs)	X (in)	Y (in)	Z (in)
3 - 10-Series	Frame+Contents	4,500	28.5	10.375	41.19

Longitudinal Anchorage Spacing (in) = 62.25

Transverse Anchorage Spacing (in) = 20.75

### Seismic Force

$S_{DS}$  = 1.0 Low & Moderate Seismic

$I_p$  = 1.0 (Importance)

$a_p$  = 1.0 (Cabinets)

$R_p$  = 2.5 (Cabinets)

$z/h$  = 0.0 (Ground Floor)

$F_p$  = 0.160 W

$F_{p,min}$  = 0.30 W

$F_{p,max}$  = 1.60 W

**Use  $F_p$  = 0.30 W**

$\Omega$  = 2.5 Overstrength

## Longitudinal Overturning

### Overturning

Moment = 0.30 (41.1875 in. x 4500lbs.) = 55,603 lb-in

### 0.9xResisting

Moment = 0.9 (4500 lbs. x 28.5 in.) = 115,425 lb-in

Anchorage Force = 0 lbs


Shear Force = 1,125 lbs/per bolt

Anchorage and Shear Force Increased by Overstrength Factor

**Design Bolts for 0 lbs tension, 1,125 lbs. shear, transverse direction**

### 10-Series unit Plan

#### Longitudinal Seismic Force



3 ganged units

Total # of bolts/Unit = 2

## Transverse Overturning

### Overturning

Moment = 0.30 (41.1875 in. x 4500lbs.) = 55,603 lb-in

### 0.9xResisting

Moment = 0.9 (4500 lbs x 10.375 in.) = 42,019 lb-in

Anchorage Force = 546 lbs/per bolt


Shear Force = 1,125 lbs/per bolt

Anchorage and Shear Force Increased by Overstrength Factor

**Design Bolts for 1 lbs tension, 1,125 lbs. shear, transverse direction**

### Ganged 10-Series unit Plan

#### Transverse Seismic Force



3 ganged units

Total # of bolts/Unit = 2

Drawing Reference See: SK4 & SK6

**Load Case: Ganged units on 18in raised computer floor (Ground Floor)**

# of Units ganged (min.)= 3

Single Unit Dimension			Raised Floor = 18 in		
Width(w) (in) =	20.75				
Depth(D) (in) =	17				
Frame Height (in) =	82.375				
Frame Weight (lb.) =	1,200				
			Center of Gravity Location		
Unit	Part	Weight (lbs)	X (in)	Y (in)	Z (in)
3 - 10-Series	Frame+Contents	3,600	28.5	10.375	59.1875

Longitudinal Anchorage Spacing (in) = 62.25  
Transverse Anchorage Spacing (in) = 20.75

**Longitudinal Overturning**

**Overturning  
Moment =**

$$0.3 (59.1875 \text{ in.} \times 3600 \text{ lbs.}) = 63,923 \text{ lb-in}$$

**0.9xResisting  
Moment =**

$$0.9 (3600 \text{ lbs.} \times 28.5 \text{ in.}) = 92,340 \text{ lb-in}$$

Anchorage Force =	0	lbs/per bolt
Shear Force =	900	lbs/per bolt

Anchorage and Shear Force Increased by Overstrength Factor

**Design Bolts for 0 lbs tension, 900 lbs. shear, longitudinal direction**

**Transverse Overturning**

**Overturning  
Moment =**

$$0.3 (59.1875 \text{ in.} \times 3600 \text{ lbs.}) = 63,923 \text{ lb-in}$$

**0.9xResisting  
Moment =**

$$0.9 (3600 \text{ lbs} \times 10.375 \text{ in.}) = 33,615 \text{ lb-in}$$

Anchorage Force =	1,217	lbs/per bolt
Shear Force =	900	lbs/per bolt

Anchorage and Shear Force Increased by Overstrength Factor

**Design Bolts for 1,217 lbs tension, 900 lbs. shear, transverse direction**

**Seismic Force**


$S_{DS} = 1.0$  Low & Moderate Seismic  
 $I_p = 1.0$  (Importance)  
 $a_p = 1.0$  (Cabinets)  
 $R_p = 2.5$  (Cabinets)  
 $z/h = 0.0$  (Ground Floor)  
 $F_p = 0.160 W$   
 $F_{p,min} = 0.30 W$   
 $F_{p,max} = 1.60 W$

**Use  $F_p = 0.30 W$**

$\Omega = 2.5$  Overstrength

**Ganged 10-Series unit Plan**

**Longitudinal Seismic Force**




3 ganged units

Total # of bolts/Unit = 2

**Ganged 10-Series unit Plan**

**Transverse Seismic Force**



3 ganged units

Total # of bolts/Unit = 2

**Drawing Reference See: SK4 & SK9**



**Load Case: Single Unit ( $\leq 50\%$  of Bldg. Ht.)**

(i.e. 2nd floor of a 4 story building or 4th floor of an 8 story building)

Unit Dimensions					
Width(w) (in) =	20.75				
Depth(D) (in) =	17				
Frame Height (in) =	82.375				
Unit Weight (lb) =	1,500				
			Center of Gravity Location		
Unit	Part	Weight (lbs)	X (in)	Y (in)	Z (in)
10-Series	Frame+Contents	1,500	8.5	10.375	41.1875

Longitudinal Anchorage Spacing (in) = 20.75  
Transverse Anchorage Spacing (in) = 17

**Longitudinal Overturning**

**Overturning  
Moment =**

$$0.32 (41.1875 \text{ in.} \times 1500 \text{ lbs.}) = 19,770 \text{ lb-in}$$

**0.9xResisting  
Moment =**

$$0.9 [1500 \text{ lbs.} \times (8.5 \text{ in.})] = 11,475 \text{ lb-in}$$


Total # of Bolts = 4

Anchorage Force =	610	lbs/per bolt
Shear Force =	600	lbs/per bolt

Anchorage and Shear Force Increased by Overstrength Factor

Seismic Force		
$S_{DS} =$	1.0	Low & Moderate Seismic
$I_p =$	1.0	(Importance)
$a_p =$	1.0	(Cabinets)
$R_p =$	2.5	(Cabinets)
$z/h =$	0.5	(50% of bldg ht.)
$F_p =$	0.320	W
$F_{p,min} =$	0.30	W
$F_{p,max} =$	1.60	W
<b>Use <math>F_p = 0.320</math> W</b>		
$\Omega =$	2.5	Overstrength

**10-Series unit Plan**



**Design Bolts for 610 lbs tension, 600 lbs. shear, longitudinal direction**

**Transverse Overturning**

**Overturning  
Moment =**

$$0.32 (41.1875 \text{ in.} \times 1500 \text{ lbs.}) = 19,770 \text{ lb-in}$$

**0.9xResisting  
Moment =**


$$0.9 [1500 \text{ lbs.} \times (10.375 \text{ in.})] = 14,006 \text{ lb-in}$$

Total # of Bolts = 4

Anchorage Force =	347	lbs/per bolt
Shear Force =	600	lbs/per bolt

Anchorage and Shear Force Increased by Overstrength Factor

**10-Series unit Plan**



**Design Bolts for 347 lbs tension, 600 lbs. shear, transverse direction**

**Drawing Reference See: SK3 & SK7**

**Load Case: Single Units on 18in Raised Comp. floor ( $\leq 50\%$  of Bldg. Ht.)**

(i.e. 2nd floor of a 4 story building or 4th floor of an 8 story building)

Unit Dimensions			Raised Floor = 18 in		
Width(w) (in) =	20.75				
Depth(D) (in) =	17				
Frame Height (in) =	82.375				
Unit Weight (lb) =	1,500				
			Center of Gravity Location		
Unit	Part	Weight (lbs)	X (in)	Y (in)	Z (in)
10-Series	Frame+Contents	1,500	8.5	10.375	59.1875

Longitudinal Anchorage Spacing (in) = 20.75  
Transverse Anchorage Spacing (in) = 17

Seismic Force		
$S_{DS}$ =	1.0	Low & Moderate Seismic
$I_p$ =	1.0	(Importance)
$a_p$ =	1.0	(Cabinets)
$R_p$ =	2.5	(Cabinets)
$z/h$ =	0.5	(50% of bldg ht.)
$F_p$ =	0.320	W
$F_{p,min}$ =	0.30	W
$F_{p,max}$ =	1.60	W
<b>Use <math>F_p</math> = 0.320 W</b>		
$\Omega$ =	2.5	Overstrength

**Longitudinal Overturning**

**Overturning  
Moment =**

$$0.32 (59.1875 \text{ in.} \times 1500 \text{ lbs.}) = 28,410 \text{ lb-in}$$


**0.9xResisting  
Moment =**

$$0.9 [1500 \text{ lbs.} \times (8.5 \text{ in.})] = 11,475 \text{ lb-in}$$

Total # of Bolts = 4

Anchorage Force = 1,245 lbs/per bolt  
Shear Force = 600 lbs/per bolt

Anchorage and Shear Force Increased by Overstrength Factor



**Design Bolts for 1,245 lbs tension, 600 lbs. shear, longitudinal direction**

**Transverse Overturning**

**Overturning  
Moment =**

$$0.32 (59.1875 \text{ in.} \times 1500 \text{ lbs.}) = 28,410 \text{ lb-in}$$


**0.9xResisting  
Moment =**

$$0.9 [1500 \text{ lbs.} \times (10.375 \text{ in.})] = 14,006 \text{ lb-in}$$

Total # of Bolts = 4

Anchorage Force = 868 lbs/per bolt  
Shear Force = 600 lbs/per bolt

Anchorage and Shear Force Increased by Overstrength Factor



**Design Bolts for 868 lbs tension, 600 lbs. shear, transverse direction**

**Drawing Reference See: SK3 & SK8**

**Load Case: Ganged Unit ( $\leq 50\%$  of Bldg. Ht.)**

# of Units ganged (max)= 3

Single Unit Dimension					
Width(w) (in) =	20.75				
Depth(D) (in) =	17				
Frame Height (in) =	82.375				
Frame Weight (lb.) =	1,300				
			Center of Gravity Location		
Unit	Part	Weight (lbs)	X (in)	Y (in)	Z (in)
3 - 10-Series	Frame+Contents	3,900	28.5	10.375	41.1875

Longitudinal Anchorage Spacing (in) = 62.25  
Transverse Anchorage Spacing (in) = 20.75

**Longitudinal Overturning**

Overturning  
Moment =

$$0.32 (82.375/2 \text{ in.} \times 3900 \text{ lbs.}) = 51,402 \text{ lb-in}$$

0.9xResisting  
Moment =

$$0.9 (3900 \text{ lbs.} \times 28.5 \text{ in.}) = 100,035 \text{ lb-in}$$

Anchorage Force =	0	lbs
Shear Force =	1,040	lbs/per bolt


Anchorage and Shear Force Increased by Overstrength Factor

**Design Bolts for 0 lbs tension, 1,040 lbs. shear, longitudinal direction**

Seismic Force		
$S_{DS}$ =	1.0	Low & Moderate Seismic
$I_p$ =	1.0	(Importance)
$a_p$ =	1.0	(Cabinets)
$R_p$ =	2.5	(Cabinets)
$z/h$ =	0.5	(50% of bldg ht.)
$F_p$ =	0.320	W
$F_{p,min}$ =	0.30	W
$F_{p,max}$ =	1.60	W
<b>Use <math>F_p</math> = 0.320 W</b>		
$\Omega$ =	2.5	Overstrength

**Ganged 10-Series unit Plan**

Longitudinal Seismic Force



3 ganged units

Total # of bolts/Unit = 2

**Transverse Overturning**

Overturning  
Moment =

$$0.32 (82.375/2 \text{ in.} \times 3900 \text{ lbs.}) = 51,402 \text{ lb-in}$$

0.9xResisting  
Moment =

$$0.9 (3900 \text{ lbs} \times 10.375 \text{ in.}) = 36,416 \text{ lb-in}$$


Anchorage Force =	602	lbs/per bolt
Shear Force =	1,040	lbs/per bolt

Anchorage and Shear Force Increased by Overstrength Factor

**Design Bolts for 602 lbs tension, 1,040 lbs. shear, transverse direction**

**Ganged 10-Series unit Plan**

Transverse Seismic Force



3 ganged units

Total # of bolts/Unit = 2

Drawing Reference See: SK4 & SK7

**Load Case: Ganged units on 18in raised computer floor (≤50% of Bldg. Ht.)**

# of Units ganged (max)= 3

Single Unit Dimension			Raised Floor = 18 in		
Width(w) (in) =	20.75				
Depth(D) (in) =	17				
Frame Height (in) =	82.375				
Frame Weight (lb.) =	1,300				
			Center of Gravity Location		
Unit	Part	Weight (lbs)	X (in)	Y (in)	Z (in)
3 - 10-Series	Frame+Contents	3,900	23	10.375	59.1875

Longitudinal Anchorage Spacing (in) = 45  
Transverse Anchorage Spacing (in) = 20.75

**Longitudinal Overturning**

**Overturning  
Moment =**

$$0.32 (59.1875 \text{ in.} \times 3900 \text{ lbs.}) = 73,866 \text{ lb-in}$$

**0.9xResisting  
Moment =**

$$0.9 (3900 \text{ lbs.} \times 22.5 \text{ in.}) = 78,975 \text{ lb-in}$$

Anchorage Force =	0	lbs/per bolt
Shear Force =	260	lbs/per bolt

Anchorage and Shear Force Increased by Overstrength Factor

**Design Bolts for 0 lbs tension, 260 lbs. shear, longitudinal direction**

**Transverse Overturning**

**Overturning  
Moment =**

$$0.3 (59.1875 \text{ in.} \times 3900 \text{ lbs.}) = 73,866 \text{ lb-in}$$

**0.9xResisting  
Moment =**

$$0.9 (3900 \text{ lbs} \times 10.375 \text{ in.}) = 36,416 \text{ lb-in}$$

Anchorage Force =	1,128	lbs/per bolt
Shear Force =	260	lbs/per bolt


Anchorage and Shear Force Increased by Overstrength Factor

**Design Bolts for 1,128 lbs tension, 260 lbs. shear, transverse direction**

Seismic Force		
$S_{DS} =$	1.0	Low & Moderate Seismic
$I_p =$	1.0	(Importance)
$a_p =$	1.0	(Cabinets)
$R_p =$	2.5	(Cabinets)
$z/h =$	0.5	(50% of bldg ht.)
$F_p =$	0.320	W
$F_{p,min} =$	0.30	W
$F_{p,max} =$	1.60	W
<b>Use <math>F_p = 0.320</math> W</b>		
$\Omega =$	2.5	Overstrength

**Ganged 10-Series unit Plan**

**Longitudinal Seismic Force**




3 ganged units

Total # of bolts/Unit = 4

**Ganged 10-Series unit Plan**

**Transverse Seismic Force**



3 ganged units

Total # of bolts/Unit = 4

Drawing Reference See: SK5 & SK8

Robinson  
Meier  
Juilly & Associates

Principals  
*Peter Robinson, S.E.*  
*Jayson E. Haines, S.E.*

# High Seismic Calculations

241 Joaquin Avenue  
San Leandro, CA 94577  
(510) 991-0977

**Find the Seismic Design Category (SDC)****Unit : 10-Series**Project Location: High Seismic  
Latitude: Varies Longitude: VariesSoil Classification: D Table 1613.5.2 & Section 1613.5.2  
Occupancy Category: II Table 1604.5

Information from U.S. Geological Survey Website

<http://earthquake.usgs.gov/research/hazmaps/>

$S_S=$	2.750	g	
$S_1=$	1.070	g	
$F_a=$	1.000		Table 1613.5.3(1)
$F_v=$	1.500		Table 1613.5.3(2)
$S_{MS}=$	2.75	g	(Equation 16-37)
$S_{M1}=$	1.61	g	(Equation 16-38)
$S_{DS}=$	1.833	g	(Equation 16-39)
$S_{D1}=$	1.070	g	(Equation 16-40)

**Seismic Design Category (SDC):** **Varies**

## Load Case: Single unit (Ground floor)

### Unit Dimensions

Width(w) (in) =	20.75
Depth(D) (in) =	17
Frame Height (in) =	82.375
Max Weight (lb.) =	800

### Center of Gravity Location

Unit	Part	Weight (lbs)	X (in)	Y (in)	Z (in)
10-Series	Frame+Contents	800	8.5	10.375	41.1875

Longitudinal Anchorage Spacing (in) = 20.75

Transverse Anchorage Spacing (in) = 17

### Seismic Force

$S_{DS}$ =	1.83	High Seismic
$I_p$ =	1.0	(Importance)
$a_p$ =	1.0	(Cabinets)
$R_p$ =	2.5	(Cabinets)
$z/h$ =	0.0	(Ground Floor)
$F_p$ =	0.293	W
$F_{p,min}$ =	0.55	W
$F_{p,max}$ =	2.93	W
<b>Use <math>F_p</math> =</b>	<b>0.550</b>	<b>W</b>
$\Omega$ =	2.5	Overstrength

## Longitudinal Overturning

### Overturning

**Moment =** 0.55 (41.1875 in. x 800lbs.) = 18,123 lb-in

### 0.9xResisting


**Moment =** 0.9 [(800 lbs. - Vert. Comp.) x 8.5in.] = 3,876 lb-in  
Vertical Component (0.2\*SDS\*Wp) = 293 lbs

Total # of Bolts = 4

Anchorage Force = 1,048 lbs/per bolt  
Shear Force = 550 lbs/per bolt

Anchorage and Shear Force Increased by Overstrength Factor

### 10-Series unit Plan



**Design Bolts for 1,048 lbs tension, 550 lbs. shear, longitudinal direction**

## Transverse Overturning

### Overturning

**Moment =** 0.55 (41.1875 in. x 800lbs.) = 18,123 lb-in

### 0.9xResisting


**Moment =** 0.9 [(800 lbs. - Vert. Comp.) x (10.375in.)] = 4,731 lb-in  
Vertical Component (0.2\*SDS\*Wp) = 293 lbs

Total # of Bolts = 4

Anchorage Force = 807 lbs/per bolt  
Shear Force = 550 lbs/per bolt

Anchorage and Shear Force Increased by Overstrength Factor

### 10-Series unit Plan



**Design Bolts for 807 lbs tension, 550 lbs. shear, longitudinal direction**

Drawing Reference See: SK3 & SK6

**Load Case: Single units on 18in raised computer floor (Ground floor)**

Unit Dimensions			Raised Floor = 18 in		
Width(w) (in) =	20.75				
Depth(D) (in) =	17				
Frame Height (in) =	82.375				
Max Weight (lb.) =	800				
			Center of Gravity Location		
Unit	Part	Weight (lbs)	X (in)	Y (in)	Z (in)
10-Series	Frame+Contents	800	8.5	10.375	59.1875

Longitudinal Anchorage Spacing (in) = 20.75  
Transverse Anchorage Spacing (in) = 17

Seismic Force		
$S_{DS}$ =	1.83	High Seismic
$I_p$ =	1.0	(Importance)
$a_p$ =	1.0	(Cabinets)
$R_p$ =	2.5	(Cabinets)
$z/h$ =	0.0	(Ground Floor)
$F_p$ =	0.293	W
$F_{p,min}$ =	0.55	W
$F_{p,max}$ =	2.93	W
<b>Use <math>F_p</math> =</b>	<b>0.550</b>	<b>W</b>
$\Omega$ =	2.5	Overstrength

**Longitudinal Overturning**

**Overturning  
Moment =**

$$0.55 (59.1875 \text{ in.} \times 800 \text{ lbs.}) = 26,043 \text{ lb-in}$$

**0.9xResisting  
Moment =**

$$0.9 [(800 \text{ lbs.} - \text{Vert. Comp.}) \times (8.5 \text{ in.})] = 3,876 \text{ lb-in}$$


$$\text{Vertical Component } (0.2 \times S_{DS} \times W_p) = 293 \text{ lbs}$$

Total # of Bolts = 4

Anchorage Force = 1,630 lbs/per bolt
Shear Force = 550 lbs./per bolt

Anchorage and Shear Force Increased by Overstrength Factor

**10-Series unit Plan**



**Design Bolts for 1,630 lbs tension, 550 lbs. shear, longitudinal direction**

**Transverse Overturning**

**Overturning  
Moment =**

$$0.55 (59.1875 \text{ in.} \times 800 \text{ lbs.}) = 26,043 \text{ lb-in}$$

**0.9xResisting  
Moment =**

$$0.9 [(800 \text{ lbs.} - \text{Vert. Comp.}) \times (10.375 \text{ in.})] = 4,731 \text{ lb-in}$$


$$\text{Vertical Component } (0.2 \times S_{DS} \times W_p) = 293 \text{ lbs}$$

Total # of Bolts = 4

Anchorage Force = 1,284 lbs/per bolt
Shear Force = 550 lbs/per bolt

Anchorage and Shear Force Increased by Overstrength Factor

**10-Series unit Plan**



**Design Bolts for 1,284 lbs tension, 550 lbs. shear, longitudinal direction**

***\*Site Specific Engineering Required\****



## Load Case: Ganged Unit (Ground floor)

# of Units ganged (min)= 3

Single Unit Dimension			Center of Gravity Location		
Unit	Part	Weight (lbs)	X (in)	Y (in)	Z (in)
Width(w) (in) =		20.75			
Depth(D) (in) =		17			
Frame Height (in) =		82.375			
Max Weight (lb.) =		1,200			
<b>3 - 10-Series</b>	Frame+Contents	3,600	29	10.375	41.1875

Seismic Force		
$S_{DS}$ =	1.83	High Seismic
$I_p$ =	1.0	(Importance)
$a_p$ =	1.0	(Cabinets)
$R_p$ =	2.5	(Cabinets)
$z/h$ =	0.0	(Ground Floor)
$F_p$ =	0.293	W
$F_{p,min}$ =	0.55	W
$F_{p,max}$ =	2.93	W
<b>Use <math>F_p</math> =</b>	<b>0.550</b>	<b>W</b>
$\Omega$ =	2.5	Overstrength

Longitudinal Anchorage Spacing (in) = 45  
Transverse Anchorage Spacing (in) = 20.75

## Longitudinal Overturning

Overturning  
Moment =

$$0.55 (41.1875 \text{ in.} \times 3600 \text{ lbs.}) = 81,551 \text{ lb-in}$$

0.9xResisting  
Moment =

$$0.9 [(3600 \text{ lbs.} - \text{Vert. Comp.}) \times 28.5 \text{ in.}] = 58,482 \text{ lb-in}$$


$$\text{Vertical Component } (0.2 \times S_{DS} \times W_p) = 1,320 \text{ lbs}$$

Anchorage Force =	320	lbs/per bolt
Shear Force =	825	lbs/per bolt

Anchorage and Shear Force Increased by Overstrength Factor

## Ganged 10-Series unit Plan

Longitudinal Seismic



3 ganged units  
Total # of bolts/Unit = 4

**Design Bolts for 320 lbs tension, 825 lbs. shear, longitudinal direction**

## Transverse Overturning

Overturning  
Moment =

$$0.55 (41.1875 \text{ in.} \times 3600 \text{ lbs.}) = 81,551 \text{ lb-in}$$

0.9xResisting  
Moment =

$$0.9 [(3600 \text{ lbs.} - \text{Vert. Comp.}) \times 10.375 \text{ in.}] = 21,290 \text{ lb-in}$$


$$\text{Vertical Component } (0.2 \times S_{DS} \times W_p) = 1,320 \text{ lbs}$$

Anchorage Force =	1,210	lbs/per bolt
Shear Force =	825	lbs/per bolt

Anchorage and Shear Force Increased by Overstrength Factor

## Ganged 10-Series unit Plan

Transverse Seismic Force



3 ganged units  
Total # of bolts/Unit = 4

**Design Bolts for 1,210 lbs tension, 825 lbs. shear, transverse direction**

Drawing Reference See: SK5 & SK6

**Load Case: Ganged units on 18in raised computer floor (Ground floor)**

# of Units ganged (min)= 3

Single Unit Dimension			Raised Floor = 18 in		
Width(w) (in) =	20.75				
Depth(D) (in) =	17				
Frame Height (in) =	82.375				
Max Weight (lb.) =	800				
			<b>Center of Gravity Location</b>		
<b>Unit</b>	<b>Part</b>	<b>Weight (lbs)</b>	<b>X (in)</b>	<b>Y (in)</b>	<b>Z (in)</b>
<b>3 - 10-Series</b>	Frame+Contents	2,400	29	10.375	59.1875

Longitudinal Anchorage Spacing (in) = 45  
Transverse Anchorage Spacing (in) = 20.75

Seismic Force		
$S_{DS}$ =	1.83	High Seismic
$I_p$ =	1.0	(Importance)
$a_p$ =	1.0	(Cabinets)
$R_p$ =	2.5	(Cabinets)
$z/h$ =	0.0	(Ground Floor)
$F_p$ =	0.293	W
$F_{p,min}$ =	0.55	W
$F_{p,max}$ =	2.93	W
<b>Use <math>F_p</math> =</b>	<b>0.550</b>	<b>W</b>
$\Omega$ =	2.5	Overstrength

**Longitudinal Overturning**

**Overturning  
Moment =**

$$0.55 (59.1875 \text{ in.} \times 2400 \text{ lbs.}) = 78,128 \text{ lb-in}$$

**0.9xResisting  
Moment =**

$$0.9 [(2400 \text{ lbs.} - \text{Vert. Comp.}) \times 28.5 \text{ in.}] = 38,988 \text{ lb-in}$$

$$\text{Vertical Component } (0.2 \times S_{DS} \times W_p) = 880 \text{ lbs}$$


Anchorage Force = 544 lbs/per bolt  
Shear Force = 550 lbs/per bolt

Anchorage and Shear Force Increased by Overstrength Factor

**Design Bolts for 544 lbs tension, 550 lbs. shear, longitudinal direction**

**Ganged 10-Series unit Plan**

Longitudinal Seismic Force



3 ganged units

Total # of bolts/Unit = 4

**Transverse Overturning**

**Overturning  
Moment =**

$$0.55 (59.1875 \text{ in.} \times 2400 \text{ lbs.}) = 78,128 \text{ lb-in}$$

**0.9xResisting  
Moment =**

$$0.9 [(2400 \text{ lbs.} - \text{Vert. Comp.}) \times 10.375 \text{ in.}] = 14,193 \text{ lb-in}$$

$$\text{Vertical Component } (0.2 \times S_{DS} \times W_p) = 880 \text{ lbs}$$


Anchorage Force = 1,284 lbs/per bolt  
Shear Force = 550 lbs/per bolt

Anchorage and Shear Force Increased by Overstrength Factor

**Design Bolts for 1,284 lbs tension, 550 lbs. shear, longitudinal direction**

**Ganged 10-Series unit Plan**

Transverse Seismic Force



3 ganged units

Total # of bolts/Unit = 4

***\*Site Specific Engineering Required\****

## Load Case: Single Unit ( $\leq 50\%$ of Bldg. Ht.)

(i.e. 2nd floor of a 4 story building or 4th floor of an 8 story building)

Unit Dimensions					
Width(w) (in) =	20.75				
Depth(D) (in) =	17				
Frame Height (in) =	82.375				
Max Weight (lb.) =	800				
			Center of Gravity Location		
Unit	Part	Weight (lbs)	X (in)	Y (in)	Z (in)
10-Series	Frame+Contents	800	8.5	10.375	41.1875

Longitudinal Anchorage Spacing (in) = 20.75

Transverse Anchorage Spacing (in) = 17

Seismic Force		
$S_{DS}$ =	1.83	High Seismic
$I_p$ =	1.0	(Importance)
$a_p$ =	1.0	(Cabinets)
$R_p$ =	2.5	(Cabinets)
$z/h$ =	0.5	(50% of bldg ht.)
$F_p$ =	0.587	W
$F_{p,min}$ =	0.55	W
$F_{p,max}$ =	2.93	W
<b>Use <math>F_p</math> =</b>	<b>0.587</b>	<b>W</b>
$\Omega$ =	2.5	Overstrength

## Longitudinal Overturning

### Overturning

**Moment =** 0.59 (41.1875 in. x 800lbs.) = 19,331 lb-in

### 0.9xResisting


**Moment =** 0.9 [(800 lbs. - Vert. Comp.) x (8.5in.)] = 3,876 lb-in  
Vertical Component (0.2\*SDS\*Wp) = 293 lbs

Total # of Bolts = 4

Anchorage Force = 1,136 lbs/per bolt  
Shear Force = 587 lbs/per bolt

Anchorage and Shear Force Increased by Overstrength Factor

### 10-Series unit Plan



**Design Bolts for 1,136 lbs tension, 587 lbs. shear, longitudinal direction**

## Transverse Overturning

### Overturning

**Moment =** 0.59 (41.1875 in. x 800lbs.) = 19,331 lb-in

### 0.9xResisting


**Moment =** 0.9 [(800 lbs. - Vert. Comp.) x (10.375in.)] = 4,731 lb-in  
Vertical Component (0.2\*SDS\*Wp) = 293 lb-in

Total # of Bolts = 4

Anchorage Force = 880 lbs/per bolt  
Shear Force = 587 lbs/per bolt

Anchorage and Shear Force Increased by Overstrength Factor

### 10-Series unit Plan



**Design Bolts for 880 lbs tension, 587 lbs. shear, longitudinal direction**

Drawing Reference See: SK5 & SK9

**Load Case: Single unit on 18in raised computer floor ( $\leq 50\%$  of Bldg. Ht.)**

(i.e. 2nd floor of a 4 story building or 4th floor of an 8 story building)

**Unit Dimensions**

Width(w) (in) =	20.75	Raised Floor =	18	in
Depth(D) (in) =	17			
Frame Height (in) =	82.375			
Max Weight (lb.) =	800			

**Center of Gravity Location**

Unit	Part	Weight (lbs)	X (in)	Y (in)	Z (in)
10-Series	Frame+Contents	800	8.5	10.375	59.1875

Longitudinal Anchorage Spacing (in) = 20.75

Transverse Anchorage Spacing (in) = 17

**Seismic Force**

$S_{DS}$ =	1.83	High Seismic
$I_p$ =	1.0	(Importance)
$a_p$ =	1.0	(Cabinets)
$R_p$ =	2.5	(Cabinets)
$z/h$ =	0.5	(50% of bldg ht.)
$F_p$ =	0.587	W
$F_{p,min}$ =	0.55	W
$F_{p,max}$ =	2.93	W
<b>Use <math>F_p</math> =</b>	<b>0.587</b>	<b>W</b>
$\Omega$ =	2.5	Overstrength

**Longitudinal Overturning**

**Overturning**

**Moment =** 0.59 (59.1875 in. x 800lbs.) = 27,779 lb-in

**0.9xResisting**


**Moment =** 0.9 [(800 lbs. - Vert. Comp.) x (8.5in)] = 3,876 lb-in  
Vertical Component (0.2\*SDS\*Wp) = 293 lbs

Total # of Bolts = 4

Anchorage Force = 1,758 lbs/per bolt  
Shear Force = 587 lbs/per bolt

Anchorage and Shear Force Increased by Overstrength Factor

**10-Series unit Plan**



**Design Bolts for 1,758 lbs tension, 587 lbs. shear, longitudinal direction**

**Transverse Overturning**

**Overturning**

**Moment =** 0.59 (59.1875 in. x 800lbs.) = 27,779 lb-in

**0.9xResisting**


**Moment =** 0.9 [(800 lbs. - Vert. Comp.) x (10.375in)] = 4,731 lb-in  
Vertical Component (0.2\*SDS\*Wp\*10.375in) = 293 lb-in

Total # of Bolts = 4

Anchorage Force = 1,388 lbs/per bolt  
Shear Force = 587 lbs/per bolt

Anchorage and Shear Force Increased by Overstrength Factor

**10-Series unit Plan**



**Design Bolts for 1,388 lbs tension, 587 lbs. shear, longitudinal direction**

**\*Site Specific Engineering Required\***

## Load Case: Ganged Unit ( $\leq 50\%$ of Bldg. Ht.)

# of Units ganged (min)= 3

### Single Unit Dimension

Width(w) (in) = 20.75

Depth(D) (in) = 17

Frame Height (in) = 82.375

Max Weight (lb.) = 1,100

### Center of Gravity Location

Unit	Part	Weight (lbs)	X (in)	Y (in)	Z (in)
3 - 10-Series	Frame+Contents	3,300	29	10.375	41.1875

Longitudinal Anchorage Spacing (in) = 45

Transverse Anchorage Spacing (in) = 20.75

### Seismic Force

$S_{DS}$  = 1.83 High Seismic

$I_p$  = 1.0 (Importance)

$a_p$  = 1.0 (Cabinets)

$R_p$  = 2.5 (Cabinets)

$z/h$  = 0.5 (50% of bldg ht.)

$F_p$  = 0.587 W

$F_{p,min}$  = 0.55 W

$F_{p,max}$  = 2.93 W

**Use  $F_p$  = 0.587 W**

$\Omega$  = 2.5 Overstrength

## Longitudinal Overturning

### Overturning

Moment = 0.59 (41.1875 in. x 3300lbs.) = 79,739 lb-in


### 0.9xResisting

Moment = 0.9 [(3300 lbs. - Vert. Comp.) x 28.5 in.] = 53,609 lb-in

Vertical Component (0.2\*SDS\*Wp) = 1,210 lbs

### Ganged 10-Series unit Plan

#### Longitudinal Seismic Force



3 ganged units

Anchorage Force = 363 lbs

Shear Force = 807 lbs/per bolt

Total # of bolts/Unit = 4

Anchorage and Shear Force Increased by Overstrength Factor

**Design Bolts for 363 lbs tension, 807 lbs. shear, longitudinal direction**

## Transverse Overturning

### Overturning

Moment = 0.59 (41.1875 in. x 3300lbs.) = 79,739 lb-in


### 0.9xResisting

Moment = 0.9 [(3300 lbs - Vert. Comp.) x 10.375 in.] = 19,515 lb-in

Vertical Component (0.2\*SDS\*Wp) = 1,210 lbs

### Ganged 10-Series unit Plan

#### Transverse Seismic Force



3 ganged units

Anchorage Force = 1,209 lbs/per bolt

Shear Force = 807 lbs/per bolt

Total # of bolts/Unit = 4

Anchorage and Shear Force Increased by Overstrength Factor

**Design Bolts for 1,209 lbs tension, 807 lbs. shear, longitudinal direction**

Drawing Reference See: SK5 & SK7

**Load Case: Ganged unit on 18in raised computer floor ( $\leq 50\%$  of Bldg. Ht.)**

# of Units ganged (min)= 3

Single Unit Dimension			Raised Floor = 18 in		
Width(w) (in) =	20.75				
Depth(D) (in) =	17				
Frame Height (in) =	82.375				
Max Weight (lb.) =	800				
			Center of Gravity Location		
Unit	Part	Weight (lbs)	X (in)	Y (in)	Z (in)
3 - 10-Series	Frame+Contents	2,400	29	10.375	59.1875

Longitudinal Anchorage Spacing (in) = 45  
Transverse Anchorage Spacing (in) = 20.75

Seismic Force		
$S_{DS}$ =	1.83	High Seismic
$I_p$ =	1.0	(Importance)
$a_p$ =	1.0	(Cabinets)
$R_p$ =	2.5	(Cabinets)
$z/h$ =	0.5	(50% of bldg ht.)
$F_p$ =	0.587	W
$F_{p,min}$ =	0.55	W
$F_{p,max}$ =	2.93	W
<b>Use <math>F_p</math> =</b>	<b>0.587</b>	<b>W</b>
$\Omega$ =	2.5	Overstrength

**Longitudinal Overturning**

**Overturning  
Moment =**

$$0.59 (59.1875 \text{ in.} \times 2400 \text{ lbs.}) = 83,336 \text{ lb-in}$$


**0.9xResisting  
Moment =**

$$0.9 (2400 \text{ lbs.} \times 28.5 \text{ in.}) = 38,988 \text{ lb-in}$$

$$\text{Vert. Comp. } (0.2 \times S_{DS} \times W_p) = 880 \text{ lbs}$$

**Ganged 10-Series unit Plan**

Longitudinal Seismic Force



3 ganged units

Anchorage Force =	616	lbs/per bolt
Shear Force =	587	lbs/per bolt

Total # of bolts/Unit = 4

Anchorage and Shear Force Increased by Overstrength Factor

**Design Bolts for 616 lbs tension, 587 lbs. shear, longitudinal direction**

**Transverse Overturning**

**Overturning  
Moment =**

$$0.59 (59.1875 \text{ in.} \times 2400 \text{ lbs.}) = 83,336 \text{ lb-in}$$


**0.9xResisting  
Moment =**

$$0.9 [(2400 \text{ lbs.} - \text{Vert. Comp.}) \times 10.375 \text{ in.}] = 14,193 \text{ lb-in}$$

$$\text{Vertical Component } (0.2 \times S_{DS} \times W_p) = 880 \text{ lb-in}$$

**Ganged 10-Series unit Plan**

Transverse Seismic Force



3 ganged units

Anchorage Force =	1,388	lbs/per bolt
Shear Force =	587	lbs/per bolt

Total # of bolts/Unit = 4

Anchorage and Shear Force Increased by Overstrength Factor

**Design Bolts for 1,388 lbs tension, 587 lbs. shear, longitudinal direction**

***\*Site Specific Engineering Required\****

Robinson  
Meier  
Juilly & Associates

Principals  
*Peter Robinson, S.E.*  
*Jayson E. Haines, S.E.*

# Drawing Details

241 Joaquin Ave.  
San Leandro, CA 94577  
(510) 991-0977

# GENERAL NOTES

## DESIGN

Design conforms to the International Building Code, 2012 Edition, & the California Building Code, 2013 Edition.

Design live loads:  
Importance Factor ..... 1.0  
Seismic Design Category (SDC).... VARIES  
Maximum Value of  $S_s$ ..... 2.75

Typical Details: and notes on these sheets shall apply unless specifically shown or noted otherwise. Construction details not fully shown or noted shall be similar to details for similar conditions. All work and construction shall comply with all applicable building codes, regulations, and safety requirements.


Discrepancies: The Contractor shall inform the Architect in writing, during the bidding period, of any discrepancies or omissions noted on the drawings or in the specifications, or of any variations needed in order to conform to codes, rules, and regulations. Upon receipt of such information, the Architect will send written instructions to all concerned. Any such discrepancy, omission, or variation not reported shall be the responsibility of the Contractor, and work shall be performed in a manner as directed by the Architect.


## EXISTING CONSTRUCTION

The Contractor shall verify all existing conditions and shall notify the Architect of all exceptions before proceeding with the work. The removal, cutting, drilling, etc. of existing work shall be performed with great care and small tools in order not to jeopardize the structural integrity of the building. If existing structural members, not indicated for removal, interfere with the new work, the Structural Engineer shall be notified immediately, and approval obtained, before removal of the existing members.

## FASTENERS


Wedge Anchors: Hilti Kwik Bolt Wedge Anchor, types as indicated per ICBO evaluation report No. 1917 or by manufacture having current ICBO evaluation report with values in shear and tension) equal or greater.



 Robinson Meier Juilly & Associates www.rmjse.com	CRENLO 10 SERIES		Job No. 14273
	LOW, MODERATE, AND HIGH SEISMIC REGIONS		Sheet No.
	Signed by MAS	Date 04/2015	(SK1)



# DESIGN SCENARIOS AND CONDITIONS



FASTENER SELECTION  
HILTI KB-TZ 1/2" Ø BOLT

## DESIGN CRITERIA

- PROVIDE SPECIAL INSPECTION FOR EXPANSION ANCHOR
- (E) CONC. MIN COMPRESSIVE STRENGTH 3,000 psi
- GROUND FLOOR
- INSTALLATION AT <50% OF BUILDING HEIGHT
- SINGLE & GANGED UNITS (3 OR MORE)
- HIGH, MODERATE & LOW SEISMIC REGIONS
- CALCULATION PER IBC 2012/CBC 2013
- IMPORTANCE FACTOR 1.0
- WEIGHT OF ENCLOSURE AND CONTENTS: SEE TABLE

ALLOWABLE CABINET ADDED WEIGHT \*ALL WEIGHTS GIVEN IN (LB) TABLE 1

MAX CABINET WT. WITH CONTENTS	LOW & MODERATE SEISMIC				HIGH SEISMIC			
	GROUND		UPPER		GROUND		UPPER	
	ON FLOOR	RAISED	ON FLOOR	RAISED	ON FLOOR	RAISED	ON FLOOR	RAISED
SINGLE UNIT	1,500	1,500	1,500	1,500	800	SS <sup>1</sup>	800	SS <sup>1</sup>
GANGED UNIT	1,500	1,200	1,500	1,500	1,200	SS <sup>1</sup>	1,200	800

SS<sup>1</sup> - SITE SPECIFIC ENGINEERING REQUIRED



**RMJ**

Robinson  
Meier  
Juilly & Associates  
www.rmjse.com

Structural Engineers

241 Joaquin Avenue  
San Leandro, CA 94577  
Tel: 510.991.0977

CRENLO  
10 SERIES

LOW, MODERATE, AND HIGH  
SEISMIC REGIONS

Signed by MAS

Date 04/2015

Job No.

14273

Sheet No.

(SK2)

**NOTES:**


- \*POSITION BOLTS IN OUTER OR UPPER HALF OF SLOTTED BOLT HOLES WHERE APPLICABLE
- \*SEE MANUFACTURE DRAWINGS FOR EXACT DIMENSIONS AND SIZE OF 10-SERIES UNITS

**CONDITION SCHEDULE**

CONDITION	SEE
CONCRETE SLAB	(SK6)
CONCRETE FILL OVER METAL DECK	(SK7)
RAISED COMP. FLOOR CONC. FILL METAL DECK	(SK8)
RAISED COMP. FLOOR CONC. SLAB	(SK9)

**INSTALLATION FOR THE FOLLOWING CONDITIONS:**

1. ALL (EXCEPT SUBBASE)

**SINGLE UNIT BOTTOM PLAN VIEW****PLAN**

1" = 1'-0"

**RMJ**

Robinson  
Meier  
Juilly & Associates  
www.rmjse.com

Structural Engineers

241 Joaquin Avenue  
San Leandro, CA 94577  
Tel: 510.991.0977

CRENLO  
10 SERIES

LOW, MODERATE, AND HIGH  
SEISMIC REGIONS

Signed by MAS

Date 04/2015

Job No.

14273

Sheet No.

(SK3)

**NOTES:**


- \*POSITION BOLTS IN OUTER OR UPPER HALF OF SLOTTED BOLT HOLES WHERE APPLICABLE
- \*SEE MANUFACTURE DRAWINGS FOR EXACT DIMENSIONS AND SIZE OF 10-SERIES UNITS

**CONDITION SCHEDULE**

CONDITION	SEE
CONCRETE SLAB	(SK6)
CONCRETE FILL OVER METAL DECK	(SK7)
RAISED COMP. FLOOR CONC. FILL METAL DECK	(SK8)
RAISED COMP. FLOOR CONC. SLAB	(SK9)

**INSTALLATION FOR THE FOLLOWING CONDITIONS:**

1. ALL (EXCEPT SUBBASE)



**GANG UNIT BOTTOM PLAN VIEW**  
**(3 UNITS OR MORE GANGED TOGETHER)**

**PLAN**  
 1" = 1'-0"



**RMJ**

Robinson  
Meier  
Juilly & Associates  
www.rmjse.com

Structural Engineers  
241 Joaquin Avenue  
San Leandro, CA 94577  
Tel: 510.991.0977

CRENLO  
10 SERIES

LOW, MODERATE, AND HIGH  
SEISMIC REGIONS

Signed by MAS

Date 04/2015

Job No.  
14273

Sheet No.

(SK4)

**NOTES:**


- \*POSITION BOLTS IN OUTER OR UPPER HALF OF SLOTTED BOLT HOLES WHERE APPLICABLE
- \*SEE MANUFACTURE DRAWINGS FOR EXACT DIMENSIONS AND SIZE OF 10-SERIES UNITS

**CONDITION SCHEDULE**

CONDITION	SEE
CONCRETE SLAB	(SK6)
CONCRETE FILL OVER METAL DECK	(SK7)
RAISED COMP. FLOOR CONC. FILL METAL DECK	(SK8)
RAISED COMP. FLOOR CONC. SLAB	(SK9)

**INSTALLATION FOR THE FOLLOWING CONDITIONS:**

1. ALL (EXCEPT SUBBASE)



**GANG UNIT BOTTOM PLAN VIEW**  
**(3 UNITS OR MORE GANGED TOGETHER)**

**PLAN**  
 1" = 1'-0"

1  
 SK5



**RMJ**

Robinson  
 Meier  
 Juilly & Associates  
 www.rmjse.com

Structural Engineers

241 Joaquin Avenue  
 San Leandro, CA 94577  
 Tel: 510.991.0977

CRENLO  
 10 SERIES

LOW, MODERATE, AND HIGH  
 SEISMIC REGIONS


Signed by MAS

Date 04/2015

Job No.  
 14273

Sheet No.

(SK5)



CONCRETE SLAB  
INSTALLATION


**DETAIL**

3" = 1' - 0"

1  
SK6



<b>RMJ</b> Robinson Meier Juilly & Associates www.rmjse.com	CRENLO 10 SERIES		Job No. 14273
	LOW, MODERATE, AND HIGH SEISMIC REGIONS		Sheet No.
	Signed by MAS	Date 04/2015	(SK6)



CONCRETE FILL OVER  
METAL DECK INSTALLATION


**DETAIL**

3" = 1' - 0"

1  
SK7



<b>RMJ</b> Robinson Meier Juilly & Associates www.rmjse.com	CRENLO 10 SERIES		Job No. 14273
	LOW, MODERATE, AND HIGH SEISMIC REGIONS		Sheet No.
	Signed by MAS	Date 04/2015	(SK7)



**RAISED COMPUTER OVER CONC.  
FILLED METAL DECK INSTALLATION**

**DETAIL**

3" = 1' - 0"

1

SK8



**RMJ**

Robinson  
Meier  
Juilly & Associates  
www.rmjse.com

Structural Engineers  
241 Joaquin Avenue  
San Leandro, CA 94577  
Tel: 510.991.0977

CRENLO  
10 SERIES

LOW, MODERATE, AND HIGH  
SEISMIC REGIONS


Signed by MAS

Date 04/2015

Job No.  
14273

Sheet No.

SK8



**RAISED COMPUTER OVER  
CONC. SLAB INSTALLATION**

**DETAIL**

**3" = 1'-0"**

**1**

**SK9**



**RMJ**

Robinson  
Meier  
Juilly & Associates  
www.rmjse.com

Structural Engineers  
241 Joaquin Avenue  
San Leandro, CA 94577  
Tel: 510.991.0977

CRENLO  
10 SERIES

LOW, MODERATE, AND HIGH  
SEISMIC REGIONS

Signed by MAS

Date 04/2015

Job No.  
14273

Sheet No.

**SK9**



Robinson  
Meier  
Juilly & Associates

Principals  
*Peter Robinson, S.E.*  
*Jayson E. Haines, S.E.*

# Appendix

241 Joaquin Avenue  
San Leandro, CA 94577  
(510) 991-0977

Company: RMJ  
 Specifier: Mario  
 Address: 241 Joaquin Ave.  
 Phone | Fax: 510.991.0977 |  
 E-Mail: msigala@rmjse.com

Page: 1  
 Project: Creno-10-Series  
 Sub-Project | Pos. No.: 14273  
 Date: 4/6/2015

**Specifier's comments:** 10-Series: SINGLE ANCHOR, Maximum Shear 1,490# 100% Capacity

## 1 Input data

### Anchor type and diameter:

**Kwik Bolt TZ - CS 1/2 (2)**

### Effective embedment depth:

$h_{ef,act} = 2.000$  in.,  $h_{nom} = 2.375$  in.

### Material:

Carbon Steel

### Evaluation Service Report:

ESR-1917

### Issued | Valid:

5/1/2013 | 5/1/2015

### Proof:

Design method ACI 318-11 / Mech.

### Stand-off installation:

$e_b = 0.000$  in. (no stand-off);  $t = 0.250$  in.

### Anchor plate:

$l_x \times l_y \times t = 3.000$  in.  $\times$   $3.000$  in.  $\times$   $0.250$  in.; (Recommended plate thickness: not calculated)

### Profile:

no profile

### Base material:

cracked concrete, 3000,  $f'_c = 3000$  psi;  $h = 4.000$  in.

### Installation:

hammer drilled hole, Installation condition: Dry

### Reinforcement:

tension: condition B, shear: condition B; no supplemental splitting reinforcement present


### Seismic loads (cat. C, D, E, or F)

Tension load: yes (D.3.3.4.3 (d))

Shear load: yes (D.3.3.5.3 (c))



### Geometry [in.] & Loading [lb, in.lb]



Company: RMJ  
 Specifier: Mario  
 Address: 241 Joaquin Ave.  
 Phone | Fax: 510.991.0977 |  
 E-Mail: msigala@rmjse.com

Page: 2  
 Project: Creno-10-Series  
 Sub-Project | Pos. No.: 14273  
 Date: 4/6/2015


## 2 Load case/Resulting anchor forces

Load case: Design loads

### Anchor reactions [lb]

Tension force: (+Tension, -Compression)

Anchor	Tension force	Shear force	Shear force x	Shear force y
1	0	1490	0	1490
max. concrete compressive strain:		- [%o]		
max. concrete compressive stress:		- [psi]		
resulting tension force in (x/y)=(0.000/0.000):		0 [lb]		
resulting compression force in (x/y)=(0.000/0.000):		0 [lb]		



## 3 Tension load

	Load $N_{ua}$ [lb]	Capacity $\phi N_n$ [lb]	Utilization $\beta_N = N_{ua} / \phi N_n$	Status
Steel Strength*	N/A	N/A	N/A	N/A
Pullout Strength*	N/A	N/A	N/A	N/A
Concrete Breakout Strength**	N/A	N/A	N/A	N/A

\* anchor having the highest loading    \*\*anchor group (anchors in tension)

Company: RMJ  
 Specifier: Mario  
 Address: 241 Joaquin Ave.  
 Phone | Fax: 510.991.0977 |  
 E-Mail: msigala@rmjse.com

Page: 3  
 Project: Creno-10-Series  
 Sub-Project | Pos. No.: 14273  
 Date: 4/6/2015

## 4 Shear load

	Load $V_{ua}$ [lb]	Capacity $\phi V_n$ [lb]	Utilization $\beta_v = V_{ua}/\phi V_n$	Status
Steel Strength*	1490	3572	42	OK
Steel failure (with lever arm)*	N/A	N/A	N/A	N/A
Pryout Strength**	1490	1844	81	OK
Concrete edge failure in direction y+**	1490	1499	100	OK

\* anchor having the highest loading \*\*anchor group (relevant anchors)

### 4.1 Steel Strength

$V_{sa,eq}$  = ESR value refer to ICC-ES ESR-1917  
 $\phi V_{steel} \geq V_{ua}$  ACI 318-11 Table D.4.1.1

#### Variables

n	$A_{se,V}$ [in. <sup>2</sup> ]	$f_{uta}$ [psi]
1	0.10	106000

#### Calculations

$$\frac{V_{sa,eq} [lb]}{5495}$$

#### Results

$V_{sa,eq}$ [lb]	$\phi_{steel}$	$\phi V_{sa}$ [lb]	$V_{ua}$ [lb]
5495	0.650	3572	1490

### 4.2 Pryout Strength

$$V_{cp} = k_{cp} \left[ \left( \frac{A_{Nc}}{A_{Nc0}} \right)^{1/3} \psi_{ec,N} \psi_{c,N} \psi_{cp,N} N_b \right] \quad \text{ACI 318-11 Eq. (D-40)}$$

$$\phi V_{cp} \geq V_{ua} \quad \text{ACI 318-11 Table D.4.1.1}$$

$$A_{Nc} \text{ see ACI 318-11, Part D.5.2.1, Fig. RD.5.2.1(b)}$$

$$A_{Nc0} = 9 h_{ef}^2 \quad \text{ACI 318-11 Eq. (D-5)}$$

$$\psi_{ec,N} = \left( \frac{1}{1 + \frac{2 e_N}{3 h_{ef}}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-8)}$$

$$\psi_{ed,N} = 0.7 + 0.3 \left( \frac{c_{a,min}}{1.5 h_{ef}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-10)}$$

$$\psi_{cp,N} = \text{MAX} \left( \frac{c_{a,min}}{c_{ac}}, \frac{1.5 h_{ef}}{c_{ac}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-12)}$$

$$N_b = k_c \lambda_a \sqrt{f'_c} h_{ef}^{1.5} \quad \text{ACI 318-11 Eq. (D-6)}$$

#### Variables

$k_{cp}$	$h_{ef}$ [in.]	$e_{c1,N}$ [in.]	$e_{c2,N}$ [in.]	$c_{a,min}$ [in.]
1	2.000	0.000	0.000	5.500

$\psi_{c,N}$	$c_{ac}$ [in.]	$k_c$	$\lambda_a$	$f'_c$ [psi]
1.000	5.500	17	1.000	3000

#### Calculations

$A_{Nc}$ [in. <sup>2</sup> ]	$A_{Nc0}$ [in. <sup>2</sup> ]	$\psi_{ec1,N}$	$\psi_{ec2,N}$	$\psi_{ed,N}$	$\psi_{cp,N}$	$N_b$ [lb]
36.00	36.00	1.000	1.000	1.000	1.000	2634

#### Results

$V_{cp}$ [lb]	$\phi_{concrete}$	$\phi_{seismic}$	$\phi_{nonductile}$	$\phi V_{cp}$ [lb]	$V_{ua}$ [lb]
2634	0.700	1.000	1.000	1844	1490

Company: RMJ  
 Specifier: Mario  
 Address: 241 Joaquin Ave.  
 Phone | Fax: 510.991.0977 |  
 E-Mail: msigala@rmjse.com

Page: 4  
 Project: Creno-10-Series  
 Sub-Project | Pos. No.: 14273  
 Date: 4/6/2015

### 4.3 Concrete edge failure in direction y+

$$V_{cb} = \left( \frac{A_{Vc}}{A_{Vc0}} \right) \psi_{ed,V} \psi_{c,V} \psi_{h,V} \psi_{parallel,V} V_b \quad \text{ACI 318-11 Eq. (D-30)}$$

$$\phi V_{cb} \geq V_{ua} \quad \text{ACI 318-11 Table D.4.1.1}$$

$$A_{Vc} \text{ see ACI 318-11, Part D.6.2.1, Fig. RD.6.2.1(b)}$$

$$A_{Vc0} = 4.5 c_{a1}^2 \quad \text{ACI 318-11 Eq. (D-32)}$$

$$\psi_{ec,V} = \left( \frac{1}{1 + \frac{2e_v}{3c_{a1}}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-36)}$$

$$\psi_{ed,V} = 0.7 + 0.3 \left( \frac{c_{a2}}{1.5c_{a1}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-38)}$$

$$\psi_{h,V} = \sqrt{\frac{1.5c_{a1}}{h_a}} \geq 1.0 \quad \text{ACI 318-11 Eq. (D-39)}$$

$$V_b = \left( 7 \left( \frac{l_e}{d_a} \right)^{0.2} \sqrt{d_a} \right) \lambda_a \sqrt{f'_c} c_{a1}^{1.5} \quad \text{ACI 318-11 Eq. (D-33)}$$

#### Variables

$c_{a1}$ [in.]	$c_{a2}$ [in.]	$e_{cV}$ [in.]	$\psi_{c,V}$	$h_a$ [in.]
3.667	5.500	0.000	1.000	4.000
$l_e$ [in.]	$\lambda_a$	$d_a$ [in.]	$f'_c$ [psi]	$\psi_{parallel,V}$
2.000	1.000	0.500	3000	1.000

#### Calculations

$A_{Vc}$ [in. <sup>2</sup> ]	$A_{Vc0}$ [in. <sup>2</sup> ]	$\psi_{ec,V}$	$\psi_{ed,V}$	$\psi_{h,V}$	$V_b$ [lb]
44.00	60.50	1.000	1.000	1.173	2512

#### Results

$V_{cb}$ [lb]	$\phi_{concrete}$	$\phi_{seismic}$	$\phi_{nonductile}$	$\phi V_{cb}$ [lb]	$V_{ua}$ [lb]
2142	0.700	1.000	1.000	1499	1490

## 5 Warnings

- Load re-distributions on the anchors due to elastic deformations of the anchor plate are not considered. The anchor plate is assumed to be sufficiently stiff, in order not to be deformed when subjected to the loading! Input data and results must be checked for agreement with the existing conditions and for plausibility!
- Condition A applies when supplementary reinforcement is used. The  $\Phi$  factor is increased for non-steel Design Strengths except Pullout Strength and Pryout strength. Condition B applies when supplementary reinforcement is not used and for Pullout Strength and Pryout Strength. Refer to your local standard.
- Refer to the manufacturer's product literature for cleaning and installation instructions.
- Checking the transfer of loads into the base material and the shear resistance are required in accordance with ACI 318 or the relevant standard!
- An anchor design approach for structures assigned to Seismic Design Category C, D, E or F is given in ACI 318-11 Appendix D, Part D.3.3.4.3 (a) that requires the governing design strength of an anchor or group of anchors be limited by ductile steel failure. If this is NOT the case, the connection design (tension) shall satisfy the provisions of Part D.3.3.4.3 (b), Part D.3.3.4.3 (c), or Part D.3.3.4.3 (d). The connection design (shear) shall satisfy the provisions of Part D.3.3.5.3 (a), Part D.3.3.5.3 (b), or Part D.3.3.5.3 (c).
- Part D.3.3.4.3 (b) / part D.3.3.5.3 (a) requires that the attachment the anchors are connecting to the structure be designed to undergo ductile yielding at a load level corresponding to anchor forces no greater than the controlling design strength. Part D.3.3.4.3 (c) / part D.3.3.5.3 (b) waives the ductility requirements and requires that the anchors shall be designed for the maximum tension / shear that can be transmitted to the anchors by a non-yielding attachment. Part D.3.3.4.3 (d) / part D.3.3.5.3 (c) waives the ductility requirements and requires the design strength of the anchors to equal or exceed the maximum tension / shear obtained from design load combinations that include E, with E increased by  $\Omega_0$ .
- Hilti post-installed anchors shall be installed in accordance with the Hilti Manufacturer's Printed Installation Instructions (MPII). Reference ACI 318-11, Part D.9.1

**Fastening meets the design criteria!**


Company: RMJ  
 Specifier: Mario  
 Address: 241 Joaquin Ave.  
 Phone | Fax: 510.991.0977 |  
 E-Mail: msigala@rmjse.com

Page: 5  
 Project: Creno-10-Series  
 Sub-Project | Pos. No.: 14273  
 Date: 4/6/2015

## 6 Installation data

Anchor plate, steel: -  
 Profile: no profile; 0.000 x 0.000 x 0.000 in.  
 Hole diameter in the fixture:  $d_f = 0.563$  in.  
 Plate thickness (input): 0.250 in.  
 Recommended plate thickness: not calculated  
 Cleaning: Manual cleaning of the drilled hole according to instructions for use is required.

Anchor type and diameter: Kwik Bolt TZ - CS 1/2 (2)  
 Installation torque: 480.001 in.lb  
 Hole diameter in the base material: 0.500 in.  
 Hole depth in the base material: 2.625 in.  
 Minimum thickness of the base material: 4.000 in.



### Coordinates Anchor in.

Anchor	x	y	c <sub>x</sub>	c <sub>+x</sub>	c <sub>y</sub>	c <sub>+y</sub>
1	0.000	0.000	5.500	5.500	5.500	5.500

Company: RMJ  
 Specifier: Mario  
 Address: 241 Joaquin Ave.  
 Phone | Fax: 510.991.0977 |  
 E-Mail: msigala@rmjse.com

Page: 1  
 Project: Creno-10-Series  
 Sub-Project | Pos. No.: 14273  
 Date: 4/6/2015

**Specifier's comments:** 10-Series: SINGLE ANCHOR, Maximum Tension 1,275# 100% Capacity

## 1 Input data

### Anchor type and diameter:

**Kwik Bolt TZ - CS 1/2 (2)**



Effective embedment depth:

$h_{ef,act} = 2.000$  in.,  $h_{nom} = 2.375$  in.

Material:

Carbon Steel

Evaluation Service Report:

ESR-1917

Issued | Valid:

5/1/2013 | 5/1/2015

Proof:

Design method ACI 318-11 / Mech.

Stand-off installation:

$e_b = 0.000$  in. (no stand-off);  $t = 0.250$  in.

Anchor plate:

$l_x \times l_y \times t = 3.000$  in.  $\times$   $3.000$  in.  $\times$   $0.250$  in.; (Recommended plate thickness: not calculated)

Profile:

no profile

Base material:

cracked concrete, 3000,  $f'_c = 3000$  psi;  $h = 4.000$  in.

Installation:

hammer drilled hole, Installation condition: Dry

Reinforcement:

tension: condition B, shear: condition B; no supplemental splitting reinforcement present


edge reinforcement: none or  $\leq$  No. 4 bar

Seismic loads (cat. C, D, E, or F)

Tension load: yes (D.3.3.4.3 (d))

Shear load: yes (D.3.3.5.3 (c))

### Geometry [in.] & Loading [lb, in.lb]



Company: RMJ  
 Specifier: Mario  
 Address: 241 Joaquin Ave.  
 Phone | Fax: 510.991.0977 |  
 E-Mail: msigala@rmjse.com

Page: 2  
 Project: Creno-10-Series  
 Sub-Project | Pos. No.: 14273  
 Date: 4/6/2015


## 2 Load case/Resulting anchor forces

Load case: Design loads

### Anchor reactions [lb]

Tension force: (+Tension, -Compression)

Anchor	Tension force	Shear force	Shear force x	Shear force y
1	1275	0	0	0
max. concrete compressive strain: - [%]				
max. concrete compressive stress: - [psi]				
resulting tension force in (x/y)=(0.000/0.000): 1275 [lb]				
resulting compression force in (x/y)=(0.000/0.000): 0 [lb]				



## 3 Tension load

	Load $N_{ua}$ [lb]	Capacity $\phi N_n$ [lb]	Utilization $\beta_N = N_{ua} / \phi N_n$	Status
Steel Strength*	1275	8029	16	OK
Pullout Strength*	N/A	N/A	N/A	N/A
Concrete Breakout Strength**	1275	1284	100	OK

\* anchor having the highest loading \*\*anchor group (anchors in tension)

### 3.1 Steel Strength

$N_{sa}$  = ESR value refer to ICC-ES ESR-1917  
 $\phi N_{steel} \geq N_{ua}$  ACI 318-11 Table D.4.1.1

#### Variables

n	$A_{se,N}$ [in. <sup>2</sup> ]	$f_{uta}$ [psi]
1	0.10	106000

#### Calculations

$N_{sa}$ [lb]
10705

#### Results

$N_{sa}$ [lb]	$\phi_{steel}$	$\phi N_{sa}$ [lb]	$N_{ua}$ [lb]
10705	0.750	8029	1275



Company: RMJ  
 Specifier: Mario  
 Address: 241 Joaquin Ave.  
 Phone | Fax: 510.991.0977 |  
 E-Mail: msigala@rmjse.com

Page: 3  
 Project: Creno-10-Series  
 Sub-Project | Pos. No.: 14273  
 Date: 4/6/2015

### 3.2 Concrete Breakout Strength

$$N_{cb} = \left( \frac{A_{Nc}}{A_{Nc0}} \right) \psi_{ed,N} \psi_{c,N} \psi_{cp,N} N_b \quad \text{ACI 318-11 Eq. (D-3)}$$

$$\phi N_{cb} \geq N_{ua} \quad \text{ACI 318-11 Table D.4.1.1}$$

$$A_{Nc} \text{ see ACI 318-11, Part D.5.2.1, Fig. RD.5.2.1(b)}$$

$$A_{Nc0} = 9 h_{ef}^2 \quad \text{ACI 318-11 Eq. (D-5)}$$

$$\psi_{ec,N} = \left( \frac{1}{1 + \frac{2 e_N}{3 h_{ef}}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-8)}$$

$$\psi_{ed,N} = 0.7 + 0.3 \left( \frac{c_{a,min}}{1.5 h_{ef}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-10)}$$

$$\psi_{cp,N} = \text{MAX} \left( \frac{c_{a,min}}{c_{ac}}, \frac{1.5 h_{ef}}{c_{ac}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-12)}$$

$$N_b = k_c \lambda_a \sqrt{f'_c} h_{ef}^{1.5} \quad \text{ACI 318-11 Eq. (D-6)}$$

#### Variables

$h_{ef}$ [in.]	$e_{c1,N}$ [in.]	$e_{c2,N}$ [in.]	$c_{a,min}$ [in.]	$\psi_{c,N}$
2.000	0.000	0.000	3.000	1.000
$c_{ac}$ [in.]	$k_c$	$\lambda_a$	$f'_c$ [psi]	
5.500	17	1.000	3000	

#### Calculations

$A_{Nc}$ [in. <sup>2</sup> ]	$A_{Nc0}$ [in. <sup>2</sup> ]	$\psi_{ec1,N}$	$\psi_{ec2,N}$	$\psi_{ed,N}$	$\psi_{cp,N}$	$N_b$ [lb]
36.00	36.00	1.000	1.000	1.000	1.000	2634

#### Results

$N_{cb}$ [lb]	$\phi_{concrete}$	$\phi_{seismic}$	$\phi_{nonductile}$	$\phi N_{cb}$ [lb]	$N_{ua}$ [lb]
2634	0.650	0.750	1.000	1284	1275

Company: RMJ  
 Specifier: Mario  
 Address: 241 Joaquin Ave.  
 Phone | Fax: 510.991.0977 |  
 E-Mail: msigala@rmjse.com

Page: 4  
 Project: Creno-10-Series  
 Sub-Project | Pos. No.: 14273  
 Date: 4/6/2015

## 4 Shear load

	Load $V_{ua}$ [lb]	Capacity $\phi V_n$ [lb]	Utilization $\beta_v = V_{ua} / \phi V_n$	Status
Steel Strength*	N/A	N/A	N/A	N/A
Steel failure (with lever arm)*	N/A	N/A	N/A	N/A
Pryout Strength*	N/A	N/A	N/A	N/A
Concrete edge failure in direction **	N/A	N/A	N/A	N/A

\* anchor having the highest loading    \*\*anchor group (relevant anchors)

## 5 Warnings

- Load re-distributions on the anchors due to elastic deformations of the anchor plate are not considered. The anchor plate is assumed to be sufficiently stiff, in order not to be deformed when subjected to the loading! Input data and results must be checked for agreement with the existing conditions and for plausibility!
- Condition A applies when supplementary reinforcement is used. The  $\Phi$  factor is increased for non-steel Design Strengths except Pullout Strength and Pryout strength. Condition B applies when supplementary reinforcement is not used and for Pullout Strength and Pryout Strength. Refer to your local standard.
- Refer to the manufacturer's product literature for cleaning and installation instructions.
- Checking the transfer of loads into the base material and the shear resistance are required in accordance with ACI 318 or the relevant standard!
- An anchor design approach for structures assigned to Seismic Design Category C, D, E or F is given in ACI 318-11 Appendix D, Part D.3.3.4.3 (a) that requires the governing design strength of an anchor or group of anchors be limited by ductile steel failure. If this is NOT the case, the connection design (tension) shall satisfy the provisions of Part D.3.3.4.3 (b), Part D.3.3.4.3 (c), or Part D.3.3.4.3 (d). The connection design (shear) shall satisfy the provisions of Part D.3.3.5.3 (a), Part D.3.3.5.3 (b), or Part D.3.3.5.3 (c).
- Part D.3.3.4.3 (b) / part D.3.3.5.3 (a) requires that the attachment the anchors are connecting to the structure be designed to undergo ductile yielding at a load level corresponding to anchor forces no greater than the controlling design strength. Part D.3.3.4.3 (c) / part D.3.3.5.3 (b) waives the ductility requirements and requires that the anchors shall be designed for the maximum tension / shear that can be transmitted to the anchors by a non-yielding attachment. Part D.3.3.4.3 (d) / part D.3.3.5.3 (c) waives the ductility requirements and requires the design strength of the anchors to equal or exceed the maximum tension / shear obtained from design load combinations that include E, with E increased by  $\Omega_0$ .
- Hilti post-installed anchors shall be installed in accordance with the Hilti Manufacturer's Printed Installation Instructions (MPII). Reference ACI 318-11, Part D.9.1

**Fastening meets the design criteria!**


Company: RMJ  
 Specifier: Mario  
 Address: 241 Joaquin Ave.  
 Phone | Fax: 510.991.0977 |  
 E-Mail: msigala@rmjse.com

Page: 5  
 Project: Creno-10-Series  
 Sub-Project | Pos. No.: 14273  
 Date: 4/6/2015

## 6 Installation data

Anchor plate, steel: -  
 Profile: no profile; 0.000 x 0.000 x 0.000 in.  
 Hole diameter in the fixture:  $d_f = 0.563$  in.  
 Plate thickness (input): 0.250 in.  
 Recommended plate thickness: not calculated  
 Cleaning: Manual cleaning of the drilled hole according to instructions for use is required.

Anchor type and diameter: Kwik Bolt TZ - CS 1/2 (2)  
 Installation torque: 480.001 in.lb  
 Hole diameter in the base material: 0.500 in.  
 Hole depth in the base material: 2.625 in.  
 Minimum thickness of the base material: 4.000 in.



### Coordinates Anchor in.

Anchor	x	y	c <sub>x</sub>	c <sub>+x</sub>	c <sub>y</sub>	c <sub>+y</sub>
1	0.000	0.000	3.000	3.000	3.000	3.000